

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

# NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Peetz Windows and Doors, Inc. 15951 S.W. 41 Street, Suite 150 Weston, FL 33331

#### Scope:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series ""European"" Outswing Glazed Wood Doors - L.M.I.

APPROVAL DOCUMENT: Drawing No. 1440 Rev B, titled "European Outswing Impact Wood Door", sheets 1 through 9 of 9, dated MAR 16, 2015, prepared by W. W. Schafer Engineering & Consulting, P. A., signed and sealed by Warren W. Schafer, P. E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and Expiration date by the Miami-Dade County Product Control Section.

# MISSILE IMPACT RATING: Large and Small Missile Impact Resistant Limitations:

- 1. Hinges to be located 8" from top or bottom of frame and not to exceed =27" O.C.
- 2. Grouted CMU is required at side jambs.
- 3. Partial Raised panels are limited to max 27.625" W x 41. 594" H
- 4. Peetz Horizontal mullion (under separate NOA) to be reviewed by Building official. Lower Design Pressure shall control the entire assembly.

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, Kall/Eifel, Germany and series and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises & renews NOA #14-0429.03 and consists of this page 1 and evidence pages E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by Ishaq I. Chanda, P.E.



NOA No. 15-0312.02 Expiration Date: December 22, 2020 Approval Date: June 11, 2015

Page 1

### NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

- A. DRAWINGS (Submitted under files# see below)
  - 1. Manufacturer's die drawings and sections.
  - 2. Drawing No. **1440 REV B,** titled "European Outswing Impact Wood Door", sheets 1 through 9 of 9, dated MAR 16, 2015, prepared by W. W. Schafer Engineering & Consulting, P. A., signed and sealed by Warren W. Schafer, P.E.
- B. TESTS (Submitted under files#14-0429.03/#11-1024.17 /#10-0615.06)
  - 1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
    - 2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
    - 3) Water Resistance Test, per FBC, TAS 202-94
    - 4) Large Missile Impact Test per FBC, TAS 201-94
    - 5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
    - 6) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94

along with the manufacturer's parts drawings, installation diagram and marked-up drawings of a outswing wood door prepared by Hurricane Test Laboratory, Inc. Test Report No. HTL-0284-0527-03, dated 05/22-28/03, signed and sealed by Vinu J. Abraham, P.E.

#### C. CALCULATIONS

- 1. Anchor verification calculations complying w/ FBC-2014 (5<sup>th</sup> edition), dated MAR 16, 2015, prepared, signed and sealed by Warren W. Schafer, P.E.
- 2. Glazing complies with ASTME-1300-02, -04 & -09.

## D. QUALITY ASSURANCE

1. Miami Dade Department of Regulatory and Economic Resources (RER).

#### E. MATERIAL CERTIFICATIONS

- 1. Notice of Acceptance No. 12-1231.08 issued to Eastman Chemical Co(MA) former Solutia Inc, for "Saflex CP: Saflex & Saflex HP Composite Glass Interlayer w/ PET", expiring on 12/11/2018.
- 2. Notice of Acceptance No. 12-1231.09 issued to Eastman Chemical Co (MA) former Solutia Inc. for "Saflex Clear or colored interlayer", expiring on May 21, 2016.

#### F. STATEMENTS

- 1. Statement letter of conformance to FBC 2014(5<sup>th</sup> Edition) and letter of no financial interest, prepared by W. W. Schaefer Engineering & Consulting, P.A., dated April 15, 2014, signed and sealed by Warren W. Schaefer, P.E.
- 2. Statement letter, prepared by W. W. Schaefer Engineering & Consulting, P.A. dated MAR 16, 2015, stating that NOA Drawings and calculation have been reviewed to 2014 FBC and found compliant, signed and sealed by Warren W. Schaefer, P.E.
- 3. Statement letters of conformance to FBC 2014(5<sup>th</sup> edition) dated MAR 16, 2015, prepared by W. W. Schafer Engineering & Consulting, P. A., signed and sealed by Warren W. Schafer, P.E. (
- 4. Distributor Agreement dated August 18, 2010, between Helmut Peetz, GMBH and Peetz Windows and Doors, Inc., signed respectively by Christian Peetz, President of Helmut Peetz, GmbH, and by Eva Leon, V. P. of Peetz Windows and Doors, Inc. (submitted under file #11-1024.17)
- 5. Lab compliance as part of the above referenced test report.


#### G. OTHER

- 1. This NOA revises & renews NOA #14-0429.03, expiring on 12/22/20.
- 2. Test Proposals # 03-0230, approved by BCCO.

Ishaq I. Chanda, P.E.

Product Control Examiner NOA No. 15-0312.02

Expiration Date: December 22, 2020 Approval Date: June 11, 2015



(2) SILL CONCRETE SCREWS SHALL BE 1/4" ELCO ULTRACONS (C.S.), ELCO CRETE-FLEX (S.S.), ITW

RAMSET/RED HEAD TAPCONS (C.S. OR S.S.) OR HILTI KWIK-CON II (C.S OR S.S.).

1440 [] SHEET NO. 1 OF 9

